



CONFIDENTIAL

~~CONFIDENTIAL~~

The still exerts approximately one half of the resistance of the whole system, which corresponds to a back pressure of 200-280 millimeters of mercury in the still.

Already in 1927-29 a new still having a greater submergence of vapor outlet orifices (about 60 millimeters) and wide vapor outlets (900 millimeters) had been installed at one of the plants. The experiment was successful, but no advantage was taken of the result elsewhere. The increase of the area of outlet orifices and the reduction of the depth of bubbling have their limits, however. A still of the Donetz plant having a great number of conduits or slots (20 instead of 13) and a slot submergence approaching zero did not distill ammonia efficiently and used too much steam. This necessitated alterations comprising a reduction of the number of vapor outlets and an increase of their submergence by 30-50 millimeters.

In order to reduce the resistance to gas flow in the reheater, replacement of reheaters of the bubble plate column type with scrubbers is being attempted. Carbon dioxide is distilled less efficiently in columns of the scrubber type, however. The condensers and coolers of the reheaters do not impede the flow of gas to an appreciable extent and may be disregarded in this instance.

As far as the absorption and washing equipment are concerned, it must be noted that the brine absorbs ammonia with extreme facility -- consequently any type of equipment can be used. With purified brine scrubber type absorbers can be used successfully, although in practice scrubbers are used chiefly for washing out residual ammonia from gases, i.e., as washers. Abroad the practice of using spray type absorbers and scrubber type washers has been introduced.

The spray absorber is in many respects similar to the absorber-cooler installed at Donsoda (APM-CH). The latter consists of two sections: an upper scrubber section and a lower section equipped with horizontal pipes through which the cooling water circulates. Both gas and liquid flow from top to bottom. In the scrubber section absorption of ammonia takes place under evolution of heat, while in the lower section the solution is cooled very effectively due to the increased temperature gradient. Resistance to gas flow is very low -- much lower than that in a column of the usual scrubber type.

Spray type absorbers have also distinct drawbacks, among which the following may be listed:

1. The difficulty of cleaning cooling surfaces. Frequent replacements of tubes is necessary.
2. In view of the fact that the volume of liquid in the tower is low, the material balance (i.e., the resulting concentration of ammonia in the liquid) is more easily upset than in a bubble type absorber. In other words, greater fluctuations of ammonia concentration occur.
3. Construction of a spray absorber is more complicated and the resulting cost is higher than that of any other absorber.
4. The height of the absorber is greater than that of a bubble type absorber, so that replacement in old installations is difficult.

Additional advantages of the spray type scrubbers comprise straight flow and monophasic operation. Straight flow means that liquid entering the absorber does not have to be pumped anywhere else until it has been completely saturated with ammonia. By monophasic operation is meant the condition that only one unit instead of several is used for the operation. Both monophasic operation and straight flow can be also achieved with a bubble plate type absorber, however.

- 2 -

~~CONFIDENTIAL~~

CONFIDENTIAL

50X1-HUM

CONFIDENTIAL

It follows from the above that spray type absorbers can be recommended for new plants which have been designed for the conversion of purified brine.

The flow of a definite quantity of gas through the equipment is brought about by the differential between the vapor pressure in the lowest section of the still and the vapor pressure in the highest section of the washer. The vapor pressure at the bottom of the still is created by steam entering the still from steam compressors or turbines. Normally this pressure is adequate. If the productivity of the plant is to be increased, steam of a higher pressure will have to be supplied to the still. A higher rate of production will lower the pressure of the steam coming from compressors and turbines, however.

In view of the fact that it is difficult to increase the steam pressure in the still, a higher degree of evacuation at the top of the absorber (washer), implying a higher rate of operation of the vacuum pump, must be resorted to.

Another solution would be replacement of the equipment by new equipment having a lower resistance to gas flow and the use of fewer and shorter connections.

The lower resistance of the equipment at newly constructed plants can be utilized either in order to increase production or in order to effect economies of steam by lowering the pressure of the steam supplied to the still. At present an increase of soda production is more important than economies achieved by the saving of steam.

A drop in the steam pressure can be observed at any of our soda plants as soon as the production load has been reduced.

In addition to the considerations outlined above, the following points may be brought out. The practice of conducting gas from the still to the reheater over the "prelimer" cannot be justified from any point of view. If there is a danger of contamination of the bottom section of the reheater with material precipitated in the still, the same precipitated material may also clog tubes connecting the several pieces of equipment. Spray type absorbers can be installed at new plants if the absorbers are equipped with tubes of good quality and continuous and uninterrupted operation of the plants is assured. Unless these two conditions are satisfied, the use of spray absorbers will only lead to higher production losses. Use of by-product steam from standard turbines for the distillation will lower the production rate if compressors or special turbines supplying high-pressure steam are replaced by standard turbines as a source of steam. In order to maintain the production rate with standard turbines, the number of units must be increased. Knowing the hydrostatic pressure and the resistance to gas flow in any unit, one can easily determine the productivity of that unit on the basis of the conditions which exist at some particular plant.

- E N D -

CONFIDENTIAL

- 3 -

CONFIDENTIAL